

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY

✓ (WATER ANALYSIS REPORT)

REF. NO:- 67 SAMPLE PROVIDED BY:- Innocent Hearts School
Pathankot Road, Naupur - Jd.


REF. DT. 13/2/24 SAMPLE COLLECTED:-

SR. NO.	TEST	REQUIRED LIMIT IS10500	SAMPLE (1)	SAMPLE (2)	SAMPLE (3)	SAMPLE (4)
1	COLOUR	5 HAZEN	Colourless			
2	ODOUR	UNOBJECTIONABLE	Odourless			
3	TASTE	AGREEABLE	No smell			
4	PH	6.5-8.5	6.7			
5	TOTAL HARDNESS AS CaCO ₃	300 mg/l	22.0			
6	DISSOLVED SOLIDS(TDS)	500 ppm	60.0			
7	ALKALINITY	200 mg/l	30.0			
8	CALCIUM AS Ca ⁺⁺	75 mg/l	10.0			
9	IRON	0.3 mg/l	0.1			
10	CHLORIDE	250 mg/l	16.0			
11	SULPHATE	150 mg/l	-			
12	NITRATES	4.5 mg/l	Nd			
13	RESIDUAL CHLORINE	0.2 mg/l	Nd			
14	FLUORIDE	1.0 mg/l	Nd			
15	LEAD"	0.05 mg/l	-			
	BACTERIAL TEST					
	TOTAL COLIFORM COUNT		/			
	BY MPN METHOD PER 100ML		Nd			
	TOTAL E-COLI COUNT		/			
	BY MPN METHOD PER 100ML		Nd			

REMARKS:-

Provided sample found satisfactory as per the applied tests.




 Analyst
 Municipal Corporation
 15/2/24

OFFICE OF CIVIL SURGEON,
JALANDHAR

CERTIFICATE

No: 465

Date: 15-12-2023

TO WHOM IT MAY CONCERN

Certified that the team of Health Inspectors inspected the "Innocent Hearts School, Nurpur, Pathankot Road, Jalandhar". On the basis of report given by team, it is certified that the hygienic conditions of the "Innocent Hearts School, Nurpur, Pathankot Road, Jalandhar" is good at present.

Signature
15/12/2023
Civil Surgeon, Jalandhar.

Date: 15-12-2023

Place: Jalandhar